

**CITY OF TUKWILA
PUBLIC WORKS PROJECT REVIEW COMMENTS**

www.ci.tukwila.wa.us
Development Guidelines and Design and Construction Standards

Permit #: D04-425
Project Name: Container Properties, LLC
9229 E Marginal Wy S
Review #: 1
Date: 12.02.2004
Reviewer: L. Jill Mosqueda, P.E.

The City Of Tukwila Public Works Department (PW) has the following comments regarding your application for the above permit. Please contact me at 206.431.2449, if you have any questions.

1. PW issues a Type C permit as part of the building permit. For the Type C permit, PW collects a base application and plan review fee when the application is submitted. The fee pays for two reviews and two inspections. Public Works charges for additional reviews and inspections.
2. Please refer to [www.ci.tukwila.wa.us/Development Guidelines and Design and Construction Standards](http://www.ci.tukwila.wa.us/Development%20Guidelines%20and%20Design%20and%20Construction%20Standards) (Chapter 3 and Appendix C) and provide plans that show:
 - a) All existing buildings, utilities, easements, etc.
 - b) Structures and utilities that will remain,
 - c) Location of capping or disconnection of each utility. For a permanent disconnection, tap the water and sewer at the main. For a temporary disconnection, you may cap at the property line.

NOTICE: IF THE DOCUMENT IN THIS FRAME IS LESS CLEAR THAN
THIS NOTICE IT IS DUE TO THE QUALITY OF THE DOCUMENT.

